

Nederlands Meetinstituut

# Test certificate

Number **TC2949** revision 3  
 Project number 302720  
 Page 1 of 5

Issued by NMI Certin B.V.  
 Hugo de Grootplein 1  
 3314 EG Dordrecht  
 The Netherlands

Notified Body Number 0122

In accordance with Paragraph 8.1 of the European Standard on Metrological aspects of non-automatic weighing instruments EN 45501:1992/AC:1993 and by application of the OIML International Recommendation R 60 (Edition 1991). The applied error fraction  $p_1$ , meant in the paragraph 3.5.4. of the standard is 0.7.

Applicant Vishay Tedea-Huntleigh Ltd.  
 5a Hatzoran St.,  
 Netanya, 42506  
 Israel

In respect of The model of a **single point, bending beam load cell**, with strain gauges, tested as a part of a weighing instrument.  
 Manufacturer : Tedea-Huntleigh  
 Type : 1042 and 1042 Symmetric

## Characteristics

Maximum capacity ( $E_{max}$ )	3, 5, 7, 10, 15, 20, 30, 50, 75, 100, 150 and 250 kg					
	Symmetric range 20, 30, 35, 50, 75, 100, 150 and 250 kg					
Accuracy Class	C					
Maximum number of load cell intervals (n)	1000	2000	3000	4000	5000*	6000*
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	3333	6666	15000	15000	15000*	20000*
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$ for $E_{max}$ 3 kg up to and including 75 kg	1200	2400	3600	4800	5200*	6200*
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$ for $E_{max}$ 100 kg up to and including 250 kg	24000					

\* only for the symmetric range


Nederlands Meetinstituut  
 Hugo de Grootplein 1  
 3314 EG Dordrecht  
 Telephone +31 78 6332332  
 Telefax +31 78 6332309

NMI B.V.  
 (Chamber of Commerce no.27.228.701)

Subsidiary companies:  
 NMI Van Swinden Laboratorium B.V. (27228703)  
 NMI Certin B.V. (27.233.418)  
 Vindroot B.V. (27.228.700)

This document is issued under the provision that NMI, B.V., nor its subsidiary companies accept any liability.

Reproduction of the complete document is allowed. Parts of the document may only be reproduced after written permission



Nederlands Meetinstituut

# Test certificate

Number **TC2949** revision 3  
Project number 302720  
Page 2 of 5


In the description TC2949 revision 3 further characteristics are described.

**Description and documentation** The load cell is described in the description number TC2949 revision 3 and documented in the documentation folder number TC2949-2, appertaining to this test certificate.

**Remarks** Summary of the test involved: see Appendix number TC2949 revision 3.  
This revision replaces the earlier version, except for its documentation folder.

Delft, 19 May 2003  
NMI Certin B.V.

P.P.M. van Enckevort  
Manager Certification Delft



## 1 General Information about the load cell

All properties of the load cell, whether mentioned or not, may not be in conflict with the standard mentioned in the test certificate.

### 1.1 Essential parts

Description	Drawing number	Rev.	Remarks
General dimensions	474.000.00-3	0	Mechanical
Wired sensor 3.....30 kg	474.200.00-2	0	Electrical
Wired sensor 50.....100 kg	474.201.00-2	0	Electrical
Model 1042 Symmetric Load cell	474.919.00-4	A	Mechanical
Model 1042 Symmetric Load cell	474.919.30-2	B	Electrical

#### Cable:

- The load cell is provided with a 4 or 6-wire system.
- Because no "remote-sensing" is used by the 4-wire system that cable length has to correspond with the cable length mentioned on the descriptive plate of the load cell.
- The cable should be a shielded cable, the shield is not connected to the load cell.

### 1.2 Essential characteristics

Minimum dead load	: 0 kg
Safe overload	: 150 % of $E_{max}$
Rated Output	: 2 mV/V $\pm$ 0.2 mV/V
Input impedance	: 415 $\Omega$ $\pm$ 20 $\Omega$
Output impedance	: 353 $\Omega$ $\pm$ 5 $\Omega$
Recommended excitation	: 10 V DC/AC
Excitation maximum	: 15 V DC/AC
Transducer material	: Aluminium of Anodised Aluminium
Atmospheric protection	: Adhesive Silicone rubber (IP66 or IP67)



Nederlands Meetinstituut

# Description

Number **TC2949** revision 3  
Project number 302720  
Page 4 of 5


## 1.3 Essential shapes

The load cell is built according to the drawing numbers: 474.000.00-3, and 474.919.00-4.

The data plate is sealed against removal or will be destroyed when removed. The data plate mentions at least the information and markings as described in the OIML R60 document. In the countries where it is mandatory the load cell should bear this test certificate number: TC2949.


### Securing:

The connecting cable of the load cell or the junction box is provided with possibility to seal.



Tests carried out for this test certificate:

Test	Institute	type, version, remarks
Temperature test and repeatability (20, 40, -10 and 20 °C)	NMi Certin B.V	1042 5kg C4, 50 kg C4 1042 Symmetric 20 kg C6 1042 Symmetric 100 kg C6
Temperature effect on minimum dead load output (20, 40, -10 and 20 °C)	NMi Certin B.V	1042 5kg C4, 50 kg C4 1042 Symmetric 20 kg C6 1042 Symmetric 100 kg C6
Creep test (20, 40 and -10 °C)	NMi Certin B.V	1042 5kg C4, 50 kg C4 1042 Symmetric 20 kg C6 1042 Symmetric 100 kg C6
Minimum load output return (20, 40 and -10 °C)	NMi Certin B.V	1042 5kg C4, 50 kg C4 1042 Symmetric 20 kg C6 1042 Symmetric 100 kg C6
Barometric pressure test at room temperature	NMi Certin B.V	Not applicable
Humidity test	NMi Certin B.V.	1042 5kg C4, 50 kg C4 for C6 calculated



Nederlands Meetinstituut

**Member State**  
The Netherlands

**OIML Certificate N° R60/2000-NL1-03.11**

Project number 302720

Page 1 of 3

## OIML CERTIFICATE OF CONFORMITY

### Issuing authority

**Name:** NMI Certin B.V.  
**Address:** Hugo de Grootplein 1, Dordrecht  
**Person responsible:** P.P.M. van Enckevort

### Applicant


**Name:** Vishay Tedeo-Huntleigh Ltd.  
**Address:** 5a Hatzoran St.,  
Netanya, 42506  
Israel

### Manufacturer of the certified pattern

**Name:** Vishay Tedeo-Huntleigh Ltd.  
**Address:** 5a Hatzoran St.,  
Netanya, 42506  
Israel

### Identification of the certified pattern

**Type** : 1042 and 1042 Symmetric  
**Fraction** :  $P_1 = 0.7$   
**Temperature range** -10 °C / +40 °C



Nederlands Meetinstituut

Member State  
The Netherlands

OIML Certificate N° R60/2000-NL1-03.11

Project number 302720


Page 2 of 3

Maximum capacity ( $E_{max}$ )	3, 5, 7, 10, 15, 20, 30, 50, 75, 100, 150 and 250 kg					
	Symmetric range 20, 30, 35, 50, 75, 100, 150 and 250 kg					
Accuracy Class	C					
Maximum number of load cell intervals (n)	1000	2000	3000	4000	5000*	6000*
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	3333	6666	15000	15000	15000*	20000*
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$ for $E_{max}$ 3 kg up to and including 75 kg	1200	2400	3600	4800	5200*	6200*
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$ for $E_{max}$ 100 kg up to and including 250 kg	24000					

\* only for the symmetric range

This certificate attests the conformity of the above-mentioned pattern (represented by the samples identified in the associated test report, the test certificate and the description with number TC2949 and the appertaining documentation folder), with the requirements of the following Recommendation(s) of the International Organization of Legal Metrology (OIML):

R60  
edition 2000 (E)  
for accuracy class C



Nederlands Meetinstituut

**Member State**  
The Netherlands

**OIML Certificate N° R60/2000-NL1-03.11**

Project number 302720

Page 3 of 3

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation(s).

This certificate does not bestow any form of legal international approval.

The conformity was established by tests described in the associated test report:

N° R60/1991-NL-97.03A, that includes 37 pages;

N° R60/1991-NL-97.03, that includes 35 pages;

N° R60/2000-NL-00.10, that includes 35 pages;


N° R60/2000-NL1-03.11, that includes 37 pages.

The issuing authority  
P.P.M. van Enkevort  
Manager Certification Delft



19 May 2003

The OIML member  
G.J. Faber



19 May 2003

\*  
\*\*

**Important note:** Apart from the mention of the certificate's reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or of the associated test report is not permitted, though they may be reproduced in full.